



ISO Class 2

ORLAND FIRE PROTECTION DISTRICT

Administration Center

9790 West 151st Street • Orland Park, IL 60462

708/349-0074 • Fax 708/349-0354

www.orlandfire.org

Board of Trustees:

President Christopher Evoy

Secretary Blair Rhode

Treasurer Jayne Schirmacher

Trustee John Brudnak Pres. Pro Tem

Trustee James Hickey

Acting Fire Chief

Michael Schofield

FIRE DEPARTMENT CHECK LIST FOR NEW TENANTS

FIRE EXTINGUISHERS:

Must be of a 4-A 60-BC Rating, (Dry chemical)

A minimum of one is required. More may be added; depending on size and number of exits. Locate within 5' of exit doors.

AUTOMATIC FIRE ALARM BUILDINGS:

Utilizing smoke detectors and manual pull stations.

S.D required in every enclosed room, closet, or combustible space. Pull stations at every exterior exit. Audio/visual alarms are required. Pull stations may be required.

SPRINKLERED BUILDINGS:

Utilizing fire sprinkler, a sprinkler head is required to cover 100% of the floor area. A minimum of 1 head is required in every room, closet, or combustible space.

TENANT SPACE STROBE LIGHT:

A strobe light may be required at store front, connected to the smoke detector/heat detector, kitchen hood, system or sprinkler water flow to identify problems in your space.

KEYLESS LOCK SETS FOR EGRESS:

No keyed locks on the egress side are allowed. No slide bolts, flush bolts, latches or hasps are allowed either. The exterior side of the door may be key locked.

EXIT SIGNS:

Must be dual voltage with battery back-up.

EMERGENCY LIGHTING:

Must cover the egress paths leading to exits.

ADDRESS/SUITE NO:

The letters of numbers must be 6" high on a building exterior for tenants, and 4" minimum, for interior hallway tenants.

SUPERVISION:

All alarms and sprinkler systems are to be connected to the Orland Fire Protection Dispatch Center.