



**ROBERT JURIS & ASSOCIATES**  
ARCHITECTS, LTD.

**To:** ALL INVITED BIDDERS

**Project:** Civic Center Roofing Replacement  
**Address:** 14750 Ravinia Avenue, Orland Park, IL 60462  
**Client:** Village of Orland Park  
**Architect:** Robert Juris & Associates Architects, Ltd., Frankfort, IL (815) 806-0146

**RJ&A Project #12004**

April 11, 2012

**ARCHITECTURAL ADDENDUM NO. 1**

The qualified Bidders shall acknowledge in writing on his/her Bid Form/Proposal the receipt of this Addendum.

This **Addendum No. 1** shall become a part of the **Bid Documents** (Drawings & Specifications) for this project and shall be integrated into the final **Contract Documents** to complete the Work. When the Architect issues an Addendum, it is the Bidder's responsibility to copy and insert it into the Bid Documents they have obtained from the Architect's office. It shall also be the responsibility of the Bidder to confirm that any subcontractor bidders, materials/suppliers bidders, etc. have received the addendum and acknowledge the receipt of any Addenda before acceptance by the General Contractor.

This Architectural Addendum contains ONE (1) item, and it is as follows:

**ITEM NO. 1:** All existing ballasted EPDM, built-up roofing with gravel, and white adhered PVC/TPO roofing (adjacent to the existing standing seam barrel vault) is to be removed and replaced with new 60 mil fully adhered TPO roof membrane per the drawings and specifications. Prior to the installation of the new membrane any existing roof insulation damaged during removal shall be patched in with new to match existing, and the entire roof is to be covered with a new wood fiber recovery board per drawings and specifications.

**END OF ADDENDUM NO. 1**

*12004-Addendum-Arch-01.doc*

*Prepared by: Robert L. Juris, Robert Juris & Associates, Architects Ltd.*