



Building Code Plan Review for Kiosk's, Carts & Tables at the Orland Square Mall

INCLUDE ADDITIONAL INFORMATION WITH PERMIT APPLICATION

- 106.2 SITE PLAN:** There shall be a site plan showing to scale the size and location of all new kiosks and all existing structures within 20 feet of the kiosk. Accurate dimensions shall be drawn using the required code Sections below for design standards.
- 402.5.1 Mall width:** The minimum width of the mall shall be 20 feet. There shall be a minimum of 10 feet clear exit width to a height of 8 feet between any projection of a tenant space bordering the mall and the nearest kiosk, vending machine, bench, display opening or other obstruction to means of egress travel.
- 402.10 Kiosks:** Kiosks and similar structures (temporary or permanent) shall meet the requirements of Sections 402.14.1 through 402.14.4 (shown below)
 1. **Construction:** Combustible kiosks or other structures shall not be located within the mall unless constructed of approved fireretardant-treated wood throughout.
 2. **Fire Suppression:** Kiosks and similar structures that are covered and are located within the mall shall be protected by an automatic sprinkler system installed in accordance with Chapter 9 of the Building Code. (Fire Protection Systems)
 3. **Horizontal separation:** The minimum horizontal separation between kiosks and other structures within the mall shall be 20 feet.
 4. **Maximum area:** Kiosks and similar structures shall have a maximum area of 150 square feet. **(See Exception for 60' Mall Width location)**
- 2701.1 Electrical Wiring, Equipment and Systems** shall conform to provisions of the Village of Orland Park Electrical Code (Ordinance # 3217)
- 920.2 Fire Extinguisher:** An approved portable fire extinguisher with a minimum classification of 4A-60BC, shall be installed within 75 feet unobstructed travel distance of each kiosk. Extinguishers installed in mall service corridors shall be readily accessible to the public and readily identified in accordance with the Fire Prevention Code.
- Illinois Accessibility Code 400-320. h) 1) and 400-310:** Where sales counters are provided for the distribution of goods or services to the public, at least one of each type shall have a portion of the counter which is at least 36 inches in length with a **maximum height of 34 inches above the finished floor.**