



Village of Orland Park

14700 S. Ravinia Avenue, Orland Park, IL 60462

Development Services Department

(708)-403-6221

RACK STORAGE PERMITTING REQUIREMENTS:

In an effort to assist customers with rack storage permits and expedite the process, the Village of Orland Park requires the following items for proper plan submittal.

****Note: Commodity classes' I-IV may be stocked up to a maximum of 12 feet to the top of the product, not the rack level, without a rack permit from the Village of Orland Park.***

1. Complete an **Application for Fire Protection Permit Form**. This can be located on our website.
2. Complete a **Storage and Industrial Occupancy Commodity Affidavit** form that can be located on our website. This commodity affidavit (signed by a company officer) describing the commodity that is being stored, how it is packaged, the maximum storage height (*top of the box*), if stored on pallet racks or shelves. If shelves are solid or wire mesh.
3. Provide information on plastics and hazardous materials. Complete an H.M.I.S. (Hazardous Materials Inventory Sheet if required) if hazardous materials are going to be stored. Otherwise state, "NO Hazardous Materials will be stored" on the commodity affidavit.
4. Provide scaled floor plans of the building highlighting the designated storage area and label all areas as to their use. (If racks are used, show aisle widths).
5. Elevations of the racks with storage height dimensions. Note: Four feet (4') will automatically be added to the top shelf to determine storage height.
6. Information on how product is stored? (i.e. wood pallets, plastic pallets, shelves, wire mesh).
7. Information on how product is packaged? (i.e. boxes cartons, containers). Are pallet loads shrink-wrapped?
8. If the building has a sprinkler system, determine the density. (.00/0000) (This can be found on the sprinkler riser).
9. Temperature and height from floor level of sprinkler heads in storage area.
10. If ESFR sprinklers are used, give specifications. (operating pressure, roof deck height, and K-Factor / orifice size).
11. Determine the building height.
12. Provide 1 ½ Inch Hose Connections if Storage is over 12 Feet.

This list of requirements will assist our office in determining the proper fire protection for each submittal.

Note 1: Racking Approval is required before inventory can be placed on the racks.

Note 2: Additional emergency lighting and exit signs may be required upon field inspection.