



ISO Class 2

ORLAND FIRE PROTECTION DISTRICT

Administration Center

9790 West 151st Street • Orland Park, IL 60462

708/349-0074 • Fax 708/349-0354

www.orlandfire.org

Board of Trustees:

President Christopher Evoy

Secretary Blair Rhode

Treasurer Jayne Schirmacher

Trustee John Brudnak Pres. Pro Tem

Trustee James Hickey

Acting Fire Chief

Michael Schofield

FIRE DEPARTMENT CHECK LIST FOR NEW TENANTS

- FIRE EXTINGUISHERS:** Must be of a 4-A 60-BC Rating, (Dry chemical)
A minimum of one is required. More may be added; depending on size and number of exits. Locate within 5' of exit doors.
- AUTOMATIC FIRE ALARM BUILDINGS:** Utilizing smoke detectors and manual pull stations.
S.D required in every enclosed room, closet, or combustible space. Pull stations at every exterior exit. Audio/visual alarms are required. Pull stations may be required.
- SPRINKLERED BUILDINGS:** Utilizing fire sprinkler, a sprinkler head is required to cover 100% of the floor area. A minimum of 1 head is required in every room, closet, or combustible space.
- TENANT SPACE STROBE LIGHT:** A strobe light may be required at store front, connected to the smoke detector/heat detector, kitchen hood, system or sprinkler water flow to identify problems in your space.
- KEYLESS LOCK SETS FOR EGRESS:** No keyed locks on the egress side are allowed. No slide bolts, flush bolts, latches or hasps are allowed either. The exterior side of the door may be key locked.
- EXIT SIGNS:** Must be dual voltage with battery back-up.
- EMERGENCY LIGHTING:** Must cover the egress paths leading to exits.
- ADDRESS/SUITE NO:** The letters of numbers must be 6" high on a building exterior for tenants, and 4" minimum, for interior hallway tenants.
- SUPERVISION:** All alarms and sprinkler systems are to be connected to the Orland Fire Protection Dispatch Center.